

FIRE EXTINGUISHER AUDIT CHECKLIST

COMPLETE
YOUR FORM
THEN
REMOVE
AND KEEP

Do you have enough fire extinguishers on site? Are they in the right place? Are they the right type? The handy audit will help you identify any holes in your fire-fighting provision. If you have questions on specific points, or require further guidance, call **0330 7000 777** or email **info@howleruk.com**

BUILDING UNDER CONSTRUCTION

YES NO

Do you have 1x9L Water or 6L Foam extinguisher and 1x2kg CO ₂ for every 200m ² of floor area?	<input type="checkbox"/>	<input type="checkbox"/>
Do you have a minimum of 2x9L Water or 6L Foam extinguishers for every floor of the building?	<input type="checkbox"/>	<input type="checkbox"/>
Can you reach an extinguisher within 30m of any point in the building?	<input type="checkbox"/>	<input type="checkbox"/>
Do you have a CO ₂ extinguisher within 10m of any significant electrical hazard?	<input type="checkbox"/>	<input type="checkbox"/>
Have you avoided putting Powder extinguishers inside the building except where gas risks exist?	<input type="checkbox"/>	<input type="checkbox"/>

SITE ACCOMMODATION

YES NO

Do you have 1x9L Water or 6L Foam extinguisher and 1x2kg CO ₂ for every 200m ² of floor area?	<input type="checkbox"/>	<input type="checkbox"/>
Do you have a minimum of 2x9L Water or 6L Foam extinguishers for every floor of the site?	<input type="checkbox"/>	<input type="checkbox"/>
Can you reach an extinguisher within 30m of any point in the building?	<input type="checkbox"/>	<input type="checkbox"/>
Do you have a CO ₂ extinguisher within 10m of any significant electrical risk?	<input type="checkbox"/>	<input type="checkbox"/>
Do you have a Wet Chemical extinguisher if you are using cooking oils and fats?	<input type="checkbox"/>	<input type="checkbox"/>
Do you have a fire blanket in the canteen?	<input type="checkbox"/>	<input type="checkbox"/>
Have you avoided putting Powder extinguishers inside the building except where gas risks exist?	<input type="checkbox"/>	<input type="checkbox"/>

SPECIAL RISKS

YES NO

Do you have a Powder extinguisher adjacent (but not in) the LPG Gas Cage?	<input type="checkbox"/>	<input type="checkbox"/>
Do you have a Powder extinguisher near LPG risks on site?	<input type="checkbox"/>	<input type="checkbox"/>
Does all ride-on plant have a suitable extinguisher on the vehicle?	<input type="checkbox"/>	<input type="checkbox"/>

▶ COMPLETED BY

SPECIAL RISKS

YES NO

Are suitable extinguishers provided near Hot Works?	<input type="checkbox"/>	<input type="checkbox"/>
Are there suitable Foam and/or Powder extinguishers near any fuel tanks or other fuel storage?	<input type="checkbox"/>	<input type="checkbox"/>

SPARES

YES NO

Do you have a reasonable proportion of spare extinguishers in case an extinguisher is used?	<input type="checkbox"/>	<input type="checkbox"/>
---	--------------------------	--------------------------

EXTINGUISHER PLACEMENT AND MAINTENANCE

YES NO

Are all extinguishers suitably mounted and protected?	<input type="checkbox"/>	<input type="checkbox"/>
Are all extinguishers within date with service label/tag in place, showing next due date?	<input type="checkbox"/>	<input type="checkbox"/>
Are you reviewing the provision of extinguishers as the work progresses?	<input type="checkbox"/>	<input type="checkbox"/>

COMMENTS / ACTIONS TO TAKE

© 2020 Howler UK. Whilst every effort has been made to ensure that information conveyed is accurate and not misleading, we regret that Howler UK cannot accept liability for any loss or loss perceived to have arisen from any such information. The information conveyed is not a substitute for a full Fire Risk Assessment carried out by a competent person, but acts as a simple aide-memoire for site personnel.

▶ SIGNED BY

▶ DATE

HOLE PUNCH YOUR FORM AND FILE IT SAFELY!