



HOWLER SITE ALERT SITE FIRE ALARM

LOG BOOK

Record of events

Site Address:	
Date of installation:	

**DO NOT DISCARD – ESSENTIAL INFORMATION IS CONTAINED IN THIS
LOG BOOK**

It is a condition of the warranty that this log book is utilised



RECORD OF EVENTS

System Overview	
Number of SITE ALERT units installed	
Site address / area(s) covered	
Linked configuration (units per chain, cable routing)	
Installer contact details	
Manufacturer	Howler UK 1-4 Mitchell Road, Fernside Park Wimborne BH21 7SG
Technical Support	+44 (0)303 003 1010 tech.support@howleruk.com

Regular checks

The following checks should be carried out by the user to ensure that the system remains in good working order:

Weekly: test each SITE ALERT unit in turn. Push the switch to sound the alarm, confirm the siren and strobe operate correctly, then push the switch a second time to reset.

As indicated (low-battery warning): if two LEDs illuminate on a unit's strobe, replace the 9V PP3 battery within 21 days.

Annually: replace the 9V PP3 battery in every unit, regardless of whether a low-battery warning has shown.

All checks, as well as faults, disconnections and battery replacements, should be noted in the log-book provided to show evidence of regular checks. This is a condition of the warranty.



RECORD OF EVENTS

Date	Time	Event	Action taken	By (name)	Further action required? (specify)



RECORD OF EVENTS

Date	Time	Event	Action taken	By (name)	Further action required? (specify)



RECORD OF EVENTS

Date	Time	Event	Action taken	By (name)	Further action required? (specify)



RECORD OF EVENTS

Date	Time	Event	Action taken	By (name)	Further action required? (specify)



RECORD OF EVENTS

Date	Time	Event	Action taken	By (name)	Further action required? (specify)



RECORD OF EVENTS

Date	Time	Event	Action taken	By (name)	Further action required? (specify)



RECORD OF EVENTS

Unit & Linking Installation Record

Record each SITE ALERT unit installed on site, its location, and how units are linked together.

Unit ID	Location on site	Linked to (Unit ID)	Installed by	Date installed

Names of delegates receiving handover

Site staff listed below have been shown how to test, reset and identify a low-battery warning on the SITE ALERT units.

Company Name:	
Site address:	
Name (Print)	Signature