

IMPORTANT

This SITE ALERT has been carefully packed to reach you in prime condition. In the unlikely event you should have reason to return it, please ensure it is carefully packed in its original packaging, otherwise we cannot accept liability for the product returned. We suggest you fold the carton flat and store it complete with packaging. This does not affect your statutory rights.



Operation & Maintenance Guide

Keep this guide with your site fire safety logbook

Howler UK | 1-4 Mitchell Road, Fernside Park, Wimborne, BH21 7SG
Technical Support: 0303 003 1010 | tech.support@howleruk.com

Before Installation

- Remove the fixing screw from the front of the SITE ALERT.
- Open the cover and connect the lead to the battery.
- Close the cover and replace the fixing screw. The unit is now ready for use.

Weekly Test

Push the switch to sound the alarm. Confirm the siren and strobe operate correctly, then push the switch a second time to reset. The siren will continue briefly after reset — this is normal.

Battery Care

- Powered by a single 9V PP3 battery — replace at least annually.
- Two LEDs on the strobe indicate the battery needs replacing — fit a new battery within 21 days.
- Disconnect the battery if a unit is stored for any length of time.

Linking Units

Link units using two-core cable, connecting like terminals (+ to +, – to –). Do not link more than 20 SITE ALERT units together.

Suggested Maintenance Schedule

Frequency	Task	Notes
Weekly	Functional alarm test	Push switch to sound, confirm operation, push again to reset
As indicated	Battery replacement	2 LEDs lit = replace 9V PP3 battery within 21 days
Annually	Scheduled battery replacement	Replace battery regardless of warning shown
On install	Linked-unit check	Like terminals (+/-), 2-core cable, max 20 units linked



Download the full SITE ALERT Log Book

Scan the code, or visit howleruk.com/customer-resources/site-alert-log-book, to download and print a fillable log book for your fire safety records.

The manufacturer accepts no responsibility for failure or damage if these instructions are not followed, or for any negligence on the part of the installer. The SITE ALERT must not be used for any purpose other than that for which it is designed.